


Functional Devices, Inc. | 101 Commerce Drive, Sharpsville, IN 46068

Email: sales@functionaldevices.com | Website: www.functionaldevices.com Toll Free: (800) 888-5538 | Office: (765) 883-5538 | Fax: (765) 883-7505

# **ENCLOSED UPS INTERFACE MODULE**

### PSH2C2RB10-L

UPS Power Control Center Interface Board, Status Contacts, 2.75" Track Mount in 14" x 16" x 6" Metal Enclosure















### **SPECIFICATIONS**

Operating Temperature: -30 to 140° F

Humidity Range: 5 to 95% (noncondensing)
Main Breaker ON/OFF: Switch / Breaker (10 Amp)
Approvals: UL Listed, UL916, C-UL, CE, RoHS

Dimensions: 14.000"H x 16.000"W x 6.000"D

Metal Housing with Screw Cover

Origin: Made of US and non-US parts

Line Input Status Contacts and UPS
Output Status Contacts Rated:

Output Status Contacts Rated:
10 Amp @ 277 Vac General Use
10 Amp @ 30 Vdc N/O
7 Amp @ 30 Vdc N/C
1/2 HP @ 125 Vac
1/4 HP @ 277 Vac

1000 VA @ 120 Vac Magnetic Ballast N/C

C300 Pilot Duty

16.8 VA @ 24 Vac Pilot Duty

#### Notes:

- Track mounted interface board may be ordered separately as model PSMN2C2RB10, to be used with any commercial UPS with appropriate ratings for the circuit breaker.
- · Circuit breaker for short-circuit protection.
- 14/3 Line Cord included (3').
- Use with UPS devices rated 1000 VA or less.
- Max. size: 14.000" x 10.000" x 5.500"
- 120 Vac, 600 W max., 8.3 Amp max.
- UPS is not included.
- To order a kit with a UPS, see PSH850-UPS-STAT.

### **UPS Status Contacts and LED Indicator**

The UPS status contacts and LED indicate power from the UPS. When normal power is present, the relay is energized, and the LED is on. When normal power is lost, the relay will be energized as long as the UPS can sustain it (until the UPS battery is depleted), and the LED is on.

## Input Power Status Contacts and LED Indicator

The input power status contacts and LED indicate the presence of normal power. When normal power is present, the relay is energized, and the LED is on. When normal power is lost, the relay is de-energized, and the LED is off.